



Real Time Data Acquisition And Monitoring

Site Name: Sembcorp Gayatri Power Limited

Report: Average Report

From Date: 01-01-2021T00:00:48Z To Date: 01-02-2021T10:00:48Z

Description	STACK_U1-Hg(mg/m3)	STACK_U1-NOx(mg/Nm3)	STACK_U1-SO2(mg/Nm3)	STACK_U1-SPM(mg/Nm3)
Prescribed Standards	0 - 100	0 -	0 -	0 - 150
Maximum Data	NA	450.96	2136.31	43.43
Minimum Data	NA	300.5	439.81	34.1
Geometric Mean	NA	352.16	1261.54	37.88
Median	NA	349.12	1173.22	38.08
Standard Deviation	NA	34.99	364.01	1.81
Maximum Value At Time	NA	2021-01-30 00:00:00	2021-01-06 00:00:00	2021-01-06 00:00:00
Minimum Value At Time	NA	2021-01-29 00:00:00	2021-01-30 00:00:00	2021-01-30 00:00:00
Valid Data Points	0	29	29	29
Total Data Points	31	31	31	31
Data Availability %	0.0%	93.55%	93.55%	93.55%

Sl No	Time	STACK_U1-Hg(mg/m3)	STACK_U1-NOx(mg/Nm3)	STACK_U1-SO2(mg/Nm3)	STACK_U1-SPM(mg/Nm3)
1	2021-01-01 00:00:00	NA	400.54	1525.06	39.26
2	2021-01-02 00:00:00	NA	426.48	1210.18	37.44
3	2021-01-03 00:00:00	NA	NA	NA	NA
4	2021-01-04 00:00:00	NA	315.95	1072.63	38.99
5	2021-01-05 00:00:00	NA	332.15	928.04	38.57
6	2021-01-06 00:00:00	NA	312.97	2136.31	43.43
7	2021-01-07 00:00:00	NA	314.46	933.58	36.00
8	2021-01-08 00:00:00	NA	325.32	973.08	36.14
9	2021-01-09 00:00:00	NA	315.26	1080.49	35.56
10	2021-01-10 00:00:00	NA	353.37	1126.15	35.65
11	2021-01-11 00:00:00	NA	390.18	1173.22	38.34
12	2021-01-12 00:00:00	NA	370.06	985.13	38.35
13	2021-01-13 00:00:00	NA	349.17	1037.35	36.94
14	2021-01-14 00:00:00	NA	307.72	1107.87	37.15

SI No	Time	STACK_U1-Hg(mg/m3)	STACK_U1-NOx(mg/Nm3)	STACK_U1-SO2(mg/Nm3)	STACK_U1-SPM(mg/Nm3)
15	2021-01-15 00:00:00	NA	353.60	1090.35	36.39
16	2021-01-16 00:00:00	NA	345.80	1106.50	35.91
17	2021-01-17 00:00:00	NA	347.23	1298.49	37.00
18	2021-01-18 00:00:00	NA	383.03	1051.69	36.58
19	2021-01-19 00:00:00	NA	323.64	1508.82	39.60
20	2021-01-20 00:00:00	NA	376.13	1509.82	39.82
21	2021-01-21 00:00:00	NA	349.88	1466.22	38.38
22	2021-01-22 00:00:00	NA	332.85	1475.41	38.06
23	2021-01-23 00:00:00	NA	343.19	1639.31	39.15
24	2021-01-24 00:00:00	NA	366.90	1712.33	38.63
25	2021-01-25 00:00:00	NA	365.43	1701.60	37.59
26	2021-01-26 00:00:00	NA	365.12	1689.59	38.53
27	2021-01-27 00:00:00	NA	345.69	1718.89	39.94
28	2021-01-28 00:00:00	NA	349.12	1265.19	38.98
29	2021-01-29 00:00:00	NA	300.50	621.62	38.08
30	2021-01-30 00:00:00	NA	450.96	439.81	34.10
31	2021-01-31 00:00:00	NA	NA	NA	NA

Report Details: SGPL | 2021-02-25 11:37:36 | Average Report



Real Time Data Acquisition And Monitoring

Site Name: Sembcorp Gayatri Power Limited

Report: Average Report

From Date: 01-01-2021T00:00:48Z To Date: 01-02-2021T10:00:48Z

Description	STACK_U2-Hg(mg/m3)	STACK_U2-NOx(mg/Nm3)	STACK_U2-SO2(mg/Nm3)	STACK_U2-SPM(mg/Nm3)
Prescribed Standards	0 - 100	0 -	0 -	0 - 150
Maximum Data	NA	528.49	1683.73	44.71
Minimum Data	NA	282.79	356.38	21.12
Geometric Mean	NA	393.73	1039.07	37.96
Median	NA	395.43	905.61	39.76
Standard Deviation	NA	42.68	345.33	6.17
Maximum Value At Time	NA	2021-01-30 00:00:00	2021-01-27 00:00:00	2021-01-14 00:00:00
Minimum Value At Time	NA	2021-01-01 00:00:00	2021-01-30 00:00:00	2021-01-02 00:00:00
Valid Data Points	0	29	29	29
Total Data Points	31	31	31	31
Data Availability %	0.0%	93.55%	93.55%	93.55%

SI No	Time	STACK_U2-Hg(mg/m3)	STACK_U2-NOx(mg/Nm3)	STACK_U2-SO2(mg/Nm3)	STACK_U2-SPM(mg/Nm3)
1	2021-01-01 00:00:00	NA	282.79	1209.01	25.67
2	2021-01-02 00:00:00	NA	395.43	1121.25	21.12
3	2021-01-03 00:00:00	NA	NA	NA	NA
4	2021-01-04 00:00:00	NA	319.98	1072.60	23.57
5	2021-01-05 00:00:00	NA	364.45	905.61	26.82
6	2021-01-06 00:00:00	NA	362.87	689.99	31.91
7	2021-01-07 00:00:00	NA	417.40	801.04	40.58
8	2021-01-08 00:00:00	NA	398.71	752.69	42.04
9	2021-01-09 00:00:00	NA	384.28	803.53	42.37
10	2021-01-10 00:00:00	NA	384.11	892.61	41.21
11	2021-01-11 00:00:00	NA	354.43	823.85	43.86
12	2021-01-12 00:00:00	NA	408.41	753.63	41.65
13	2021-01-13 00:00:00	NA	368.05	799.34	42.82
14	2021-01-14 00:00:00	NA	410.99	822.77	44.71

SI No	Time	STACK_U2-Hg(mg/m3)	STACK_U2-NOx(mg/Nm3)	STACK_U2-SO2(mg/Nm3)	STACK_U2-SPM(mg/Nm3)
15	2021-01-15 00:00:00	NA	415.57	824.88	42.15
16	2021-01-16 00:00:00	NA	435.38	850.73	43.59
17	2021-01-17 00:00:00	NA	413.46	1026.77	41.92
18	2021-01-18 00:00:00	NA	428.53	799.64	38.78
19	2021-01-19 00:00:00	NA	358.42	1288.83	38.67
20	2021-01-20 00:00:00	NA	394.39	1215.23	40.00
21	2021-01-21 00:00:00	NA	392.82	1350.85	38.22
22	2021-01-22 00:00:00	NA	416.72	1365.96	39.76
23	2021-01-23 00:00:00	NA	426.72	1443.23	41.07
24	2021-01-24 00:00:00	NA	435.98	1675.44	39.51
25	2021-01-25 00:00:00	NA	369.89	1633.45	37.53
26	2021-01-26 00:00:00	NA	370.34	1543.43	37.08
27	2021-01-27 00:00:00	NA	381.02	1683.73	38.30
28	2021-01-28 00:00:00	NA	401.36	1057.39	39.30
29	2021-01-29 00:00:00	NA	397.29	569.24	39.84
30	2021-01-30 00:00:00	NA	528.49	356.38	36.92
31	2021-01-31 00:00:00	NA	NA	NA	NA

Report Details: SGPL | 2021-02-25 11:39:40 | Average Report



Real Time Data Acquisition And Monitoring

Site Name: Sembcorp Gayatri Power Limited

Report: Average Report

From Date: 01-01-2021T00:00:48Z To Date: 01-02-2021T10:00:48Z

Description	Fire_station-CO(mg/m3)	Fire_station-NOx(ug/m3)	Fire_station-PM2.5(ug/m3)	Fire_station-PM10(ug/m3)	Fire_station-SO2(ug/m3)
Prescribed Standards	0 - 4	0 - 80	0 - 60	0 - 100	0 - 80
Maximum Data	0.88	7.51	43.61	46.7	18.38
Minimum Data	0.25	0.71	3.72	4.58	12.15
Geometric Mean	0.37	4.23	11.51	14.7	13.39
Median	0.36	4.78	10.0	13.55	13.18
Standard Deviation	0.12	1.89	7.36	7.99	1.05
Maximum Value At Time	2021-01-29 00:00:00	2021-01-21 00:00:00	2021-01-29 00:00:00	2021-01-29 00:00:00	2021-01-21 00:00:00
Minimum Value At Time	2021-01-04 00:00:00	2021-01-23 00:00:00	2021-01-08 00:00:00	2021-01-08 00:00:00	2021-01-26 00:00:00
Valid Data Points	28	28	28	28	28
Total Data Points	31	31	31	31	31
Data Availability %	90.32%	90.32%	90.32%	90.32%	90.32%

Sl No	Time	Fire_station-CO(mg/m3)	Fire_station-NOx(ug/m3)	Fire_station-PM2.5(ug/m3)	Fire_station-PM10(ug/m3)	Fire_station-SO2(ug/m3)
1	2021-01-01 00:00:00	0.29	4.22	14.01	19.15	12.99
2	2021-01-02 00:00:00	0.32	4.74	15.25	18.87	13.24
3	2021-01-03 00:00:00	NA	NA	NA	NA	NA
4	2021-01-04 00:00:00	0.25	4.38	6.69	8.28	13.09
5	2021-01-05 00:00:00	0.28	4.47	8.54	8.05	13.24
6	2021-01-06 00:00:00	0.29	4.53	6.62	8.25	13.26
7	2021-01-07 00:00:00	0.32	4.90	6.44	8.64	13.47
8	2021-01-08 00:00:00	0.25	5.20	3.72	4.58	13.75
9	2021-01-09 00:00:00	0.25	4.76	5.30	7.53	13.64
10	2021-01-10 00:00:00	0.34	4.94	10.98	13.89	13.79
11	2021-01-11 00:00:00	0.35	5.08	9.81	12.59	13.63
12	2021-01-12 00:00:00	0.34	4.79	10.18	13.85	12.92
13	2021-01-13 00:00:00	0.52	6.79	19.79	25.87	12.99

SI No	Time	Fire_station-CO(mg/m3)	Fire_station-NOx(ug/m3)	Fire_station-PM2.5(ug/m3)	Fire_station-PM10(ug/m3)	Fire_station-SO2(ug/m3)
14	2021-01-14 00:00:00	0.37	4.85	13.64	18.23	13.04
15	2021-01-15 00:00:00	0.40	5.45	12.41	16.04	13.44
16	2021-01-16 00:00:00	0.38	5.56	10.82	15.48	13.16
17	2021-01-17 00:00:00	0.30	5.23	7.01	10.52	13.03
18	2021-01-18 00:00:00	0.32	5.05	8.96	11.85	13.18
19	2021-01-19 00:00:00	0.36	4.53	12.01	16.27	12.79
20	2021-01-20 00:00:00	0.42	5.25	14.84	18.77	13.19
21	2021-01-21 00:00:00	0.39	7.51	11.50	14.75	18.38
22	2021-01-22 00:00:00	0.34	1.81	6.05	8.19	13.34
23	2021-01-23 00:00:00	0.36	0.71	8.27	9.36	12.96
24	2021-01-24 00:00:00	0.37	1.47	7.68	10.95	13.37
25	2021-01-25 00:00:00	0.36	1.16	8.30	11.87	12.82
26	2021-01-26 00:00:00	0.38	1.28	8.92	13.25	12.15
27	2021-01-27 00:00:00	0.42	1.11	12.90	18.12	12.83
28	2021-01-28 00:00:00	0.49	1.49	17.93	21.65	12.92
29	2021-01-29 00:00:00	0.88	7.11	43.61	46.70	14.18
30	2021-01-30 00:00:00	NA	NA	NA	NA	NA
31	2021-01-31 00:00:00	NA	NA	NA	NA	NA

Report Details: SGPL | 2021-02-25 11:43:06 | Average Report



Real Time Data Acquisition And Monitoring

Site Name: Sembcorp Gayatri Power Limited

Report: Average Report

From Date: 01-01-2021T00:00:48Z To Date: 01-02-2021T10:00:48Z

Description	Field_Hostel-CO(ppm)	Field_Hostel-NOx(ppm)	Field_Hostel-PM2.5(ug/Nm3)	Field_Hostel-PM10(ug/Nm3)	Field_Hostel-SO2(ppm)
Prescribed Standards	0 - 100	0 - 100	0 - 100	0 - 100	0 - 100
Maximum Data	2.02	7.94	23.34	31.01	5.3
Minimum Data	1.86	1.22	3.69	5.88	2.88
Geometric Mean	1.93	4.17	13.72	18.66	3.35
Median	1.94	4.57	12.92	17.55	3.2
Standard Deviation	0.05	1.41	5.52	6.82	0.5
Maximum Value At Time	2021-01-13 00:00:00	2021-01-22 00:00:00	2021-01-28 00:00:00	2021-01-28 00:00:00	2021-01-22 00:00:00
Minimum Value At Time	2021-01-25 00:00:00	2021-01-04 00:00:00	2021-01-08 00:00:00	2021-01-08 00:00:00	2021-01-02 00:00:00
Valid Data Points	29	29	29	29	29
Total Data Points	31	31	31	31	31
Data Availability %	93.55%	93.55%	93.55%	93.55%	93.55%

Sl No	Time	Field_Hostel-CO(ppm)	Field_Hostel-NOx(ppm)	Field_Hostel-PM2.5(ug/Nm3)	Field_Hostel-PM10(ug/Nm3)	Field_Hostel-SO2(ppm)
1	2021-01-01 00:00:00	1.88	1.59	19.47	26.23	2.93
2	2021-01-02 00:00:00	1.88	1.45	14.79	23.64	2.88
3	2021-01-03 00:00:00	NA	NA	NA	NA	NA
4	2021-01-04 00:00:00	1.87	1.22	7.30	11.11	2.96
5	2021-01-05 00:00:00	1.88	1.66	6.39	10.08	2.96
6	2021-01-06 00:00:00	1.88	5.03	6.94	10.35	2.90
7	2021-01-07 00:00:00	1.91	4.64	9.19	12.08	2.90
8	2021-01-08 00:00:00	1.88	4.57	3.69	5.88	2.90
9	2021-01-09 00:00:00	1.89	5.69	6.56	9.44	2.96
10	2021-01-10 00:00:00	1.94	4.58	13.18	17.55	3.02
11	2021-01-11 00:00:00	1.94	5.43	12.35	15.43	3.06
12	2021-01-12 00:00:00	1.95	4.42	12.92	16.22	3.08
13	2021-01-13 00:00:00	2.02	5.56	22.55	27.23	3.13

SI No	Time	Field_Hostel-CO(ppm)	Field_Hostel-NOx(ppm)	Field_Hostel-PM2.5(ug/Nm3)	Field_Hostel-PM10(ug/Nm3)	Field_Hostel-SO2(ppm)
14	2021-01-14 00:00:00	1.97	4.23	18.21	22.03	3.11
15	2021-01-15 00:00:00	2.00	4.74	16.61	21.57	3.15
16	2021-01-16 00:00:00	1.98	4.81	15.09	19.30	3.20
17	2021-01-17 00:00:00	1.94	3.86	10.12	14.36	3.26
18	2021-01-18 00:00:00	1.94	3.80	12.38	17.20	3.27
19	2021-01-19 00:00:00	1.96	3.24	16.54	20.90	3.35
20	2021-01-20 00:00:00	2.00	4.61	20.32	25.42	3.40
21	2021-01-21 00:00:00	1.99	4.60	15.00	22.86	3.44
22	2021-01-22 00:00:00	1.94	7.94	8.03	11.62	5.30
23	2021-01-23 00:00:00	1.88	4.60	9.23	13.22	3.58
24	2021-01-24 00:00:00	1.87	4.46	10.89	16.03	3.63
25	2021-01-25 00:00:00	1.86	3.85	11.22	17.29	3.68
26	2021-01-26 00:00:00	1.88	3.69	12.66	18.20	3.78
27	2021-01-27 00:00:00	1.89	3.24	18.73	26.48	3.77
28	2021-01-28 00:00:00	1.94	4.97	23.34	31.01	3.79
29	2021-01-29 00:00:00	1.95	4.93	22.50	29.96	3.84
30	2021-01-30 00:00:00	1.94	3.50	21.80	28.59	3.79
31	2021-01-31 00:00:00	NA	NA	NA	NA	NA

Report Details: SGPL | 2021-02-25 11:44:49 | Average Report



Real Time Data Acquisition And Monitoring

Site Name: Sembcorp Gayatri Power Limited

Report: Average Report

From Date: 01-01-2021T00:00:48Z To Date: 01-02-2021T10:00:48Z

Description	Near_Isukuduru_Village_Gate-NOx(ug/m3)	Near_Isukuduru_Village_Gate-PM2.5(ug/m3)	Near_Isukuduru_Village_Gate-PM10(ug/m3)	Near_Isukuduru_Village_Gate-SO2(ug/m3)
Prescribed Standards	0 - 80	0 - 60	0 - 100	0 - 80
Maximum Data	4.65	29.93	40.0	18.92
Minimum Data	0.43	6.13	7.36	9.13
Geometric Mean	1.45	16.18	22.67	12.62
Median	1.23	15.92	21.69	10.23
Standard Deviation	0.82	6.65	8.62	4.13
Maximum Value At Time	2021-01-22 00:00:00	2021-01-30 00:00:00	2021-01-28 00:00:00	2021-01-22 00:00:00
Minimum Value At Time	2021-01-04 00:00:00	2021-01-08 00:00:00	2021-01-08 00:00:00	2021-01-02 00:00:00
Valid Data Points	29	29	29	29
Total Data Points	31	31	31	31
Data Availability %	93.55%	93.55%	93.55%	93.55%

Sl No	Time	Near_Isukuduru_Village_Gate-NOx(ug/m3)	Near_Isukuduru_Village_Gate-PM2.5(ug/m3)	Near_Isukuduru_Village_Gate-PM10(ug/m3)	Near_Isukuduru_Village_Gate-SO2(ug/m3)
1	2021-01-01 00:00:00	0.81	22.19	30.12	9.50
2	2021-01-02 00:00:00	0.97	22.20	28.81	9.13
3	2021-01-03 00:00:00	NA	NA	NA	NA
4	2021-01-04 00:00:00	0.43	7.20	12.83	9.48
5	2021-01-05 00:00:00	0.69	7.49	11.93	9.50
6	2021-01-06 00:00:00	1.21	7.85	9.63	9.44
7	2021-01-07 00:00:00	1.45	10.54	14.95	9.52
8	2021-01-08 00:00:00	1.65	6.13	7.36	9.78
9	2021-01-09 00:00:00	0.95	8.14	10.93	9.77
10	2021-01-10 00:00:00	1.70	15.92	21.69	9.85

Sl No	Time	Near_Isukuduru_Village_Gate-NOx(ug/m3)	Near_Isukuduru_Village_Gate-PM2.5(ug/m3)	Near_Isukuduru_Village_Gate-PM10(ug/m3)	Near_Isukuduru_Village_Gate-SO2(ug/m3)
11	2021-01-11 00:00:00	1.96	14.91	19.88	9.82
12	2021-01-12 00:00:00	1.61	15.92	22.18	9.89
13	2021-01-13 00:00:00	2.99	25.47	32.80	10.21
14	2021-01-14 00:00:00	1.86	21.79	29.06	10.02
15	2021-01-15 00:00:00	1.95	17.88	24.86	10.21
16	2021-01-16 00:00:00	1.88	16.43	25.10	10.23
17	2021-01-17 00:00:00	1.30	11.35	16.55	10.34
18	2021-01-18 00:00:00	1.61	14.70	20.48	10.27
19	2021-01-19 00:00:00	1.04	19.74	26.97	10.26
20	2021-01-20 00:00:00	1.84	23.74	31.65	10.58
21	2021-01-21 00:00:00	1.84	16.33	24.46	10.27
22	2021-01-22 00:00:00	4.65	9.16	16.59	18.92
23	2021-01-23 00:00:00	1.07	10.89	15.73	18.55
24	2021-01-24 00:00:00	1.12	12.86	20.09	18.60
25	2021-01-25 00:00:00	0.63	12.55	18.63	18.60
26	2021-01-26 00:00:00	0.62	14.34	20.33	18.65
27	2021-01-27 00:00:00	0.92	20.94	30.41	18.70
28	2021-01-28 00:00:00	1.23	27.62	40.00	18.78
29	2021-01-29 00:00:00	1.00	24.92	35.83	18.71
30	2021-01-30 00:00:00	1.00	29.93	37.44	18.39
31	2021-01-31 00:00:00	NA	NA	NA	NA